

© Crown copyright and database rights 2017. Ordnance Survey 100017661.Contains Environment Agency Information © Environment Agency and database right. Licence No. 012/087SuDS A British Geological Survey © NERC & Derived in part from Source Protection Zone material:- Licence from the Environment Agency © Environment Agency 2012. All rights reserved.

Legend

Allocated Development Sites **Borough Boundary** Main River

Culverted Main River

Ordinary Watercourse

Culverted Ordinary Watercourse

Flood Zone 3 with a 70% allowance for climate change

Risk of flooding from Rivers

Flood Zone 3B Flood Zone 3 Flood Zone 2

Risk of flooding from Surface Water

High risk of flooding (3.3% AEP)

Medium Risk of flooding (1% AEP) Low risk of flooding (0.1% AEP)

Risk of flooding from groundwater

Limited potential for groundwater flooding to occur

> Potential for groundwater flooding of property situated below ground level

Potential for groundwater flooding to occur at surface

Suitability for infiltration SuDS

Highly compatible for infiltration SuDS

Probably compatible for infiltration

Opportunities for bespoke infiltration

SuDS Very significant constraints are

Flood Risk from Reservoirs

Reservoir flood extents

USE THE BUTTONS BELOW TO DISPLAY / HIDE DIFFERENT















SITE NAME: SITE LOCATION: SITE AREA: Archies Stables, Cudham LaneNorth **Cudham Lane North** 982 sq.metres

	% OF SITE	AREA (sq.m)
FLOOD ZONE 2	0	0
FLOOD ZONE 3A	0	0
FLOOD ZONE 3B	0	0

SUMMARY: The whole of the site is located within Flood Zone 1. In agreement with this, no recorded incidents of river flooding in this location are held by the Environment Agency.

	% OF SITE	AREA (sq.m)	MAX ANTICIPATED DEPTH
HIGH RISK OF FLOODING:	0	0	0m
MEDIUM RISK OF FLOODING:	0	0	0m
LOW RISK OF FLOODING:	0	0	0m

SUMMARY: The site is shown to be at 'Very Low' risk of flooding from surface water. Mitigation measures would not be required as part of any proposed development.

The site is unlikely to be suitable for infiltration SuDS and is not in the vicinity of a watercourse or surface water sewer. The proposed drainage may therefore need to connect via a private system and maximise the use of non-infiltration SUDS.

GROUNDWATER

SEWERS

ARTIFICIAL

SUMMARY

FLUVIAL (RIVERS)

SURFACE WATER

SUMMARY: The London Borough of Bromley does not hold any records of Groundwater flooding affecting the site. This is in agreement with the British Geological Survey groundwater mapping which indicates that groundwater flooding is unlikley to occur in this location.

SUMMARY: There are no surface water sewers within 50 metres of the site however there may be foul or combined sewers which could pose a residual risk to the development site in the event of blockage.

SUMMARY: The site is not in an area indicated to be at risk of flooding as a result of a reservoir breach.

SITE ALLOCATION: The 'Archies Stables, Cudham LaneNorth' site has been allocated for Traveller use and is therefore classified as 'Highly Vulnerable' in accordance with Table 2 of the Planning Practice Guidance to the National Planning Policy Framework.

PLANNING IMPLICATION: There are no Main Rivers or Ordinary Watercourses within 500m of the allocated development site. The site is entirely located within Flood Zone 1 and is therefore an appropriate location for all development types, including Traveller.

ORIGINATED	BN	15/05/2017
CHECKED	JB	16/05/2017
VERIFIED	GP	17/05/2017





PAGE: 44